

Apr 12, 1944 Mr Brown Walter & Platt

671250 per 24 hrs = 466 gals per min.

2 pumps as receiving would pump  
560 gals per min

therefore they would deal with the 24 hrs  
yield in 20 hrs pumping time

yield in 20 hrs is 560 000 ✓

Quantity pumped by 2 pumps  
in 20 hrs 672 000 ✓

difference 112 000 gals

therefore if pumping done in one shift of  
20 hrs, the Manson would have to  
store the gal of 112 000

alternative is automatic control

Population Census 1939. 7374.

(1) BROOK. MAIN STATION

DEC. 1. 1943

Wiltshire Water Supply

331 Parkers Rd  
Barn 5.

General Particulars

Dec 1<sup>st</sup> 1943.

Available supply already collected at end of September 1943

Domestic supply gauge Marshall supply 21,600 Broomwood supply  
 1.00 = 21,600 per day 1.00 gauge = 43,200 43,200 400,320 gals per day  
 400,320 gals per day = 16,430 gals per hour 400,320  
465,120 Total collected

Total amount of water used at end of September 1943 per day

1.00 = 21,600  $\frac{21,600}{43,200}$  1.00g = 43,200 2 Reservoirs running at 42 RRM for 23 hrs.  
 $\frac{848,400}{313,200}$  = 5400 per hour  $\times 23 \times 2 = 248,400$

Total Amount of Water used per day for week ending Friday Dec 10. 1943

9 gauge = 18,396 9 gauge 36,808 2 Reservoirs @ 10,000  $\times 23.64$  Total = 310,516 gals per day.

Total Amount of Water used per day for week ending Friday Dec 17. 1943

9 gauge = 18,396 9 gauge 36,808 Total 349,691 see Page 2.

Total consumption per day by all sources at end of Sept 1943 in All areas	Total consumption by all sources within V. Area per day	Total consumption as allowed supplies with V. Area per day	Total consumption used as Domestic purposes per day including smallfalls and brook.	Consumption for other purposes including smallfalls in V. Area	Consumption for other purposes including smallfalls in V. Area
From Domestic = 21,600 per day	313,200	48,700	235,201	29,391	235,201
" Marshall 43,200	29,299 less 2 Reservoirs		7,374	7,374	7,374
" Broomwood 248,400	283,901		38,596		38,596
<u>313,200</u>					

Supplies not yet collected: Railway Springs 237,600 gals per day  
 Hurne Springs 381,330 gals per day  
618,930 gals per day

Existing commitments to Rural District

Locality	Max per day	Percent Made 1/2 Year ending Sept 1943 of supply per day	Balance of supply per day	Consumption Sept 1943
Dunstone	6000	2358	3642	3277
Wootton	30000	9063	20937	9408
Marshall	7000	1382	5618	3518
Marshall	6000	4761	1239	4020
Overridge way	11,000	11,735		11,302
	<u>60,000</u>			
Wiltshire	10,000			
Wootton	5,000			
	<u>15,000</u>			
		29,299	Quarry abbots Hurne 4000	31,525



Water Supply

Present Conditions      Consumption of Water

Population according to Census 1939 was 7374.

Consumption of Water per day by all areas at end of Feb. 1943

Rural Supply	21600
Marshall Supply	43200
Worcesterwood do	248400
	<u>313200</u>

29299 less Metered supplies in Rural Area  
283901 consumed by all sources in Urban Area  
which equals 38.5 gals per head per day

48700 less Metered supplies in Urban Area  
235201 consumed by Domestic Users  
which equals 32 gals per head per day

Sources of Supply

Quantities already collected at end of Feb. 1943

Rural	21600
Marshall	43200
Worcesterwood	400320
	<u>465120</u>

Quantities not yet collected

Railway Springs	237600 gals per day
Hulme Springs	381330 gals per day
	<u>618930</u>

Present capacity of Service Reservoirs

Existing Marshall Reservoir	150000 gals
do Worcesterwood do	100000
	<u>250000 gals</u>

This figure based on the total consumption per day in all areas equals 8 times the daily consumption

The usual storage capacity of Service Reservoirs allowed for by some Water Undertakings is 3 times the daily consumption, when there is no duplicate pumping plant, and from 2 to 2½ times the daily consumption if there is duplicate pumping plant, therefore to bring the accommodation of the Service Reservoirs up to a little over twice the present  
(see over page)

Present capacity of Pumping Plant as tested on Friday Dec 31, 1943  
 Three turbines with ram pumps

Each turbine lifted at the rate of 5400 gals per hour running at 42 RPM

Two turbines running for 23.64 hours per day on Dec 10<sup>th</sup> 1943

pumped 255312 gals. which is considered the maximum

Electric Motor when tested on Friday Dec 31, 1943

pumped at the rate of 15246 gals per hour

Running the maximum of 24 hrs per day the total pumped would  
 be  $15246 \times 24 = 365904$  gals per day

at the present time however these two means of pumping cannot  
 be run at the same time owing to the capacity of the 7" Mains  
 main

Originally the 7" Mains main was designed to deliver 10000 gals per  
 hour, but is now being required to deliver 15246 gals per hour.

Three turbines running for 22 hrs per day each pumping 5000 gals per hour  
 at 40 RPM =  $5000 \times 3 \times 22 = 330000$  gals per day.

### Capacity of Mains

The existing 7" main from Westwood Reservoir to Bramshall 11720 yards long  
 and with a hydraulic gradient of 1 in 314 when new was capable of  
 discharging 288000 per 24 hrs at Bramshall, I have no reason to  
 doubt that its discharging capacity remains the same.

Total amount of Water available for consumption comes from Cromford  
 and Hulme Springs =

Already collected	400320	gals per day
Railway Spring	287600	do
Hulme Spring	381330	do

1019250

Existing 7" main discharges 288000 gals per day

A new 9" main would discharge 630000 "

918000 gals per day.

A new 10" main would discharge at Bramshall 760000 gals per day  
 therefore to make provision for conveying the balance of 931250 gals per  
 day to Uttoxeter and decided it was necessary a new 10" main from  
 Westwood, this I would suggest might be carried along the  
 opposite side of the Uttoxeter Ambourn Road, and if possible  
 (see over page)

Dec 7, 1943

in the fields between the improvement line and the building line decided up by the County Council, until it reached the shaft crossing, from whence it would be carried along the Urban Boundary until it reached the Hotters Road at the intersection of the Rye Lane road

From this point it would follow the proposed link road joining the Hotters Road with the Stone Road near Leharne Villa, and then proceed along the Stone Road to the Manshall Reservoir

The existing 7" main from Prestwood would be continued as such to Myrds Lane, at which point the portion in Myrds Lane to the Manshall Reservoir would be cut off, and the 7" main continue as at present as a 5" high pressure main supplying the Dumber Lane and Balance Hill districts

The portion of the 7" main cut off in Myrds Lane would be utilized as a distribution main from Manshall Reservoir, and continued along Holly Road to the Three Dials as a 7" main, and pick up the 3" branch in New Road and the service mains of the Council houses at a point near Johnson Road

Such main would also connect up with the 3" main in Holly Rd between Myrds Lane and Manshall Rd creating a circuit and relieving the demands at present made on the 8" delivery main from Manshall Reservoir to the Town

The portion of the down net on Stone Rd from the junction with Cornthfield Road and Carter St, Goldfields Rd Hockley Rd past Carter St past Balance Rd, and Newfold St now served from the High pressure main would be re-connected to the low pressure system



The question of increasing the Pumping plant and rising main also needs serious consideration, and in order to fund the balance of the Sprinkwood Springs, the Railway Spring and the Hubme Spring of the following amounts:

		365,904
		330,000
		2,695,904
Sprinkwood Spring Present Yield	400,320	
Sum at present pumped on	348,000	
average between 3 pumps and the Electric Motor	523,20	Balance say 348,000
		unpumped
		523,20
Railway Spring		237,600
Hubme Spring		381,930
		<u>6,712,500</u> per day

466 gals per min = 27969 per hour

\* An Electric Pump similar to the one already installed would pump 280 gals per min Duplicate to the above H.P. Motor and wiring 280 do do and would necessitate a new 9" Rising main Total per min 560 Such Duplicate Pumps would deal with the 24 hrs yield of 6,712,500 gals in 20 hrs collection of the Hubme Springs also. This would not prove to be a difficult matter, as it could be conveyed by gravitation, with the available head of 10 ft. by means of a 9" Pipe.

Collection of Railway Spring

These springs would have to be conveyed by a separate connection to the Pumpwell across the railway, and would not present any great difficulty.

\* Particulars re suggested present Floor level of No 2 Pump house 306.60  
 Bottom of Pumpwell 294.50. 2nd Water level at Westwood 512.00

Pumpwell

Provision would have to be made for a new pumpwell, and if the yield of 672000 was to be pumped in 20 hrs then would necessitate a pumpwell having a capacity of 112000 gals, which would not be economical and in order to avoid such a necessity, the pumps would have to be automatically controlled by the rise and fall on the new and smaller pumpwell.

1447 1 25

daily consumption it would necessitate building an additional Refractor  
at Marshall of 250 000 capacity, and one at Westwood of 200 000  
gals capacity, such refractors could be built in such a manner so  
as to enable them to be added to from time to time.